


Through-penetration Firestop Systems

System No. W-J-2219

April 11, 2008

F Rating — 2 Hr

T Rating — 0 Hr



1. **Wall Assembly** — Min 6 in. thick normal weight or lightweight (100-150 pcf) concrete. Wall may also be constructed of any UL Classified **Concrete Blocks***. Max diam of opening is 4 in.

See **Concrete Blocks** (CAZT) category in the Fire Resistance Directory for names of manufacturers.

2. **Nonmetallic Pipe** — One nonmetallic pipe or conduit to be installed either concentrically or eccentricity within the firestop system. The annular space between the through penetrant and the periphery of the opening shall be a min 5/8 in. to a max 1 in. Pipe or conduit to be rigidly supported on both sides of wall assembly. The following types of nonmetallic pipes or conduits may be used:

A. **Polyvinyl Chloride (PVC) Pipe** — Nom 2 in. diam (or smaller) Schedule 40 solid or cellular core PVC pipe for use in closed (process or supply) or vented (drain, waste, or vent) piping systems.

B. **Chlorinated Polyvinyl Chloride (CPVC) Pipe** — Nom 2 in. diam (or smaller) SDR 13.5 CPVC pipe for use in closed (process or supply) piping systems.

C. **Rigid Nonmetallic Conduit+** — Nom 2 in. diam (or smaller) Schedule 40 PVC conduit installed in accordance with Article 347 of the National Electrical Code, (NFPA No. 70).

D. **Acrylonitrile Butadiene Styrene (ABS) Pipe** — Nom 2 in. diam Schedule 40 cellular or solid core ABS pipe for use in closed (process or supply) or vented (drain, waste or vent) piping systems.

3. **Fill, Void, or Cavity Materials* - Sealant** — Min 5/8 in. thickness of fill material applied within the annulus, flush with both surfaces of wall. Additional fill material to be installed such that a min ¼ in. thick crown is formed around the through penetrant on both surfaces of wall.

ACCUMETRIC L L C — Boss 816

*Bearing the UL Classification Mark

